

Conduit and Trench Inspection Notice

All contractors and developers requesting underground inspections shall call the Member Solutions Department at 1-800-698-2007 a minimum of 2 business days before the trench is started to make arrangements for an on-site inspection by NHEC Construction personnel. NHEC will conduct an on-site inspection within 2 business days of the inspection request.

At the time of inspection NHEC will verify the following:

- Proper trench depth and location
- Conduit Schedule
- Installation of copper wire as required
- Conduit properly bedded in sand or select backfill

Refer to Section 2: *“Underground Service Installations, Permanent & Temporary”*

Once certification has been completed, an NHEC “approval” sticker will be placed on the conduit in order to notify all parties that the underground electrical system has been inspected and approved.

Failure to comply with this requirement will result in the system being re-exposed so that the proper inspection can be performed. No electrical service will be installed until the inspection sticker is in place.

Please be prepared to give all information regarding your project to our Member Solutions representative, including your Service Order #

_____.



**CONTACT NUMBER:
1-800-698-2007**